

Lowest allowed bending radius

in accordance with DIN VDE 0298 part 3

Nominal voltage up to 0,6 / 1kV

Cables for fixed installation	Outer diameter of cable / Thickness of flat cable in mm		
	up to 10 mm	over/up to 10-25 mm	over 25 mm
for fixed installation	4 x d	4 x d	4 x d
for internal wiring	1 x d	2 x d	3 x d

Flexible cables	Outer diameter of cable / Thickness of flat cable in mm			
	up to 8 mm	over/up to 8-12 mm	over/up to 12-20 mm	over 20 mm
for fixed installation	3 x d	3 x d	4 x d	4 x d
at free movement	3 x d	4 x d	5 x d	5 x d
at introduction	3 x d	4 x d	5 x d	5 x d

Flexible cables at restricted guidance	Outer diameter of cable / Thickness of flat cable in mm			
	up to 8 mm	over/up to 8-12 mm	over/up to 12-20 mm	over 20 mm
Drum operation	5 x d	5 x d	5 x d	6 x d
Cable trolley operation	3 x d	4 x d	5 x d	5 x d
Drag chain operation	4 x d	4 x d	5 x d	5 x d
Roller deviation	8 x d	8 x d	8 x d	8 x d